



Clean TeQ Sunrise

2020 ENVIRONMENTAL MONITORING RESULTS

SURFACE WATER MONITORING

Premises:
Clean TeQ Sunrise Project
Wilmatha Road
Fifield, NSW, 2875

[Environment Protection Licence #21146](#)

Location: SW4								
Frequency: Weekly during any discharge								
Point No: 23			pH (Lab)	pH (Field)	Total Suspended Solids (mg/L)	Electrical Conductivity (Lab) (µS/cm)	Iron (dissolved) (mg/L)	Nickel (dissolved) (mg/L)
Date Sampled	Results Received	Results Published						
05/03/20	18/03/20	03/06/20	6.4 ¹	-*	13	53	0.12	0.002
10/04/20	22/04/20	03/06/20	6.6	7.01	49	53	0.19	0.001
EPL Limits			6.5-8.5	-	50	2200	3.7	0.008

* pH meter unserviceable

¹ pH reading outside EPL limit reported to NSW EPA

Location: SW6								
Frequency: Weekly during any discharge								
Point No: 25			pH (Lab)	pH (Field)	Total Suspended Solids (mg/L)	Electrical Conductivity (Lab) (µS/cm)	Iron (dissolved) (mg/L)	Nickel (dissolved) (mg/L)
Date Sampled	Results Received	Results Published						
10/04/20	22/4/20	03/06/20	6.8	7.34	14	44	0.07	<0.001
EPL Limits			6.5-8.5	-	50	2200	3.7	0.008